

### **Tacoma Facility**

1427 E 26th Street

Tacoma, WA 98421

(253) 272-7788

### **Quincy Facility**

1302 NE Intermodal Way


Quincy, WA 98848

(509) 497-0350

# PVC SWEDGE REDUCERS



## **Bell-by-Spigot**




		-		
OAL	Α	В	С	Weight
(inch)	(inch)	(inch)	(inch)	(lbs)
2.75	1.125	1.125	0.5	0.068
3.875	1.75	1.625	0.5	0.171
4.0	1.75	1.5	0.75	0.230
4.75	2.0	2.0	0.75	0.566
4.75	2.0	2.0	0.75	0.336
6.75	2.75	3.0	1.0	0.728
7.25	3.0	3.25	1.0	1.242
8.0	3.25	3.75	1.0	1.173
9.0	4.0	3.75	1.25	1.970
10.5	4.75	4.25	1.5	3.137
11.75	5.25	4.75	1.75	4.411
	(inch) 2.75 3.875 4.0 4.75 4.75 6.75 7.25 8.0 9.0 10.5	(inch)(inch)2.751.1253.8751.754.01.754.752.04.752.06.752.757.253.08.03.259.04.010.54.75	(inch)(inch)(inch)2.751.1251.1253.8751.751.6254.01.751.54.752.02.04.752.02.06.752.753.07.253.03.258.03.253.759.04.03.7510.54.754.25	(inch)       (inch)       (inch)       (inch)         2.75       1.125       1.125       0.5         3.875       1.75       1.625       0.5         4.0       1.75       1.5       0.75         4.75       2.0       2.0       0.75         4.75       2.0       2.0       0.75         6.75       2.75       3.0       1.0         7.25       3.0       3.25       1.0         8.0       3.25       3.75       1.0         9.0       4.0       3.75       1.25         10.5       4.75       4.25       1.5

<sup>\*</sup>Other sizes available upon request

### **Finishing Options**

- 1. Bell-by-Spigot (picture to left)
- 2. Bell-by-Bell (picture below)
  - Tapered interference fit for solvent weld PVC
  - Socket per NEMA TC-3 socket entrance.
  - Optional Inner ID chamfered 0.3" min. at 45°

## **Bell-by-Bell**



Size	OAL	Α	В	С
	(inch)	(inch)	(inch)	(inch)
3 - 2	7.0	2.875	1.75	2.375
3 - 2 ½	7.75	2.875	2.5	2.375
4 - 3	8.5	3.375	2.875	2.25
5 - 4	10.0	4.0	3.375	2.625
6 - 5	11.25	4.5	4.0	2.75

#### **Advantages & Highlights of Swedge Reducers**

- Manufactured to NEMA TC-3 specifications for Polyvinyl Chloride (PVC) Fittings for Use with Rigid PVC Conduit and Tubing.
- Rigid PCD conduit and fittings covered in these requirements are intended to be joined with a cement that is or contains a solvent for polyvinyl chloride.
- Dimensions are approximate and subject to normal manufacturing tolerances.